

Geothermal Energy Use, Country Update for Portugal

João Carlos Nunes^{1*}, Luís Coelho², José Martins Carvalho³, Maria do Rosário Carvalho⁴ and João Garcia²

¹ INOVA- Instituto de Inovação Tecnológica dos Açores, Rua S. Gonçalo s/n, 9504-540 Ponta Delgada, Açores & Universidade dos Açores, Rua Mãe de Deus, 9501-801 Ponta Delgada, Açores, Portugal

² Instituto Politécnico de Setúbal (EST/IPS), Escola Superior de Tecnologia de Setúbal, Campus do IPS, Estefanilha, 2910-761 Setúbal & CINEA-IPS, Centro de Investigação em Energia e Ambiente – IPS, Setúbal, Portugal

³ Laboratório de Cartografia e Geologia Aplicada, Instituto Superior de Engenharia (ISEP), Politécnico do Porto, Rua Dr. António Bernardino de Almeida, 431, 4200-072 Porto & GeoBioTec, Universidade de Aveiro, Campus de Santiago, 3810-193 Aveiro, Portugal

⁴ Departamento de Geologia, Faculdade de Ciências, Universidade de Lisboa& Instituto D. Luiz, Campo Grande, Edifício C6, 3º Piso, 1749-016 Lisboa, Portugal

[*jcnunes@inovacores.pt](mailto:jcnunes@inovacores.pt)

Keywords: Portugal, Azores, power generation, direct uses, GSHP, shallow geothermal energy.

ABSTRACT

In Portugal, the presence of high temperature geothermal resources is restricted to the volcanic islands of Azores Archipelago, located in the North Atlantic Ocean and which are associated with the triple junction of the North American, Eurasian and African (or Nubian) plates.

Present investments at the Ribeira Grande Geothermal Field on the island of S. Miguel implemented by EDA RENOVÁVEIS S.A. company led the installed generation capacity in the island to a total of 27.8 MW, with the contribution of the Pico Vermelho plant (13 MW net), which went into operation in November 2006. On Terceira Island, the 4 MW Pico Alto pilot power plant started in operation in August 2017 and was officially inaugurated in November 2017, running regularly since then.

Thus, power production from geothermal resources in Azores presently meets 42% of the electrical consumption of the S. Miguel island, 10.8% of the electrical consumption of Terceira island, and 25.7% of the total demand of the archipelago. Power production is stabilized since 2013.

Geothermal continue to be expected to assume an even more impressive role for electric power self-sufficiency of this Autonomous Region of Portugal, particularly in S. Miguel and Terceira Islands. However, its development is now considered in conjunction with other renewable energy sources, particularly wind energy.

Low-temperature geothermal resources in Mainland Portugal are exploited for direct uses in balneotherapy and small heating systems.

In Portugal, ground source heat pump technology (GSHP) is gaining penetration in the heating and cooling of buildings market.

1. INTRODUCTION

High temperature geothermal resources in Portugal are limited to the volcanic islands of Azores (Figures 1 and 2), where have been used for power production since 1980, at the Ribeira Grande Geothermal Field (RGGF).

In spite of some minor environmental impacts, the last years were extremely relevant for geothermal in the Azores (Carvalho et al., 2013, Carvalho et al., 2015, Nunes et al., 2016), as:

- The total generation capacity installed at the RGGF was expanded from the previous 14.8 MW, mainly concentrated at the Ribeira Grande plant, to a total capacity of 27.8 MW, including the Pico Vermelho plant;
- The development of geothermal resources on the island of S. Miguel has been well succeeded, with an annual average contribution of around 42% of the electricity produced in the island since 2013;
- In 2017 started operating the 4 MW Pico Alto pilot power plant, following the evaluation tests carried out during 2013/2014 on the existing production wells in the Pico Alto Geothermal Field (PAGF).

Geothermal gained a renovated interest and assumes a leading position in the renewable energy portfolio of the island of S. Miguel and Terceira. In the scope of renewable energies utilization expansion in Azores, the regional government considers geothermal as a main player for the development of new projects for electricity generation.

The expansion of the installed capacity at the RGGF (S. Miguel island) is already scheduled to increase the

geothermal penetration on the market: more wells are to be drilled in 2020, to increase the total running capacity up to 30 MWe. Also, more wells are planned to be drilled in 2020 in the PAGF as back-up wells to the existing power plant, and if possible to increase the installed capacity in Terceira island.




Figure 1: Location of Portugal Mainland, the Azores Archipelago and S. Miguel and Terceira Islands.




Figure 2: The Azores Triple Junction area. MAR: Mid Atlantic Ridge. Shaded area represents the “Azores Plateau” (adapted from Nunes et al., 2008).

The geothermal policy in Azores issued by the Azores Government is developed in the field by the regional electric utility EDA – Electricidade dos Açores S.A., through its affiliated company EDA RENOVÁVEIS S.A. (a joint of former SOGEO - Sociedade Geotérmica dos Açores S.A. and GEOTERCEIRA - Sociedade Geoeléctrica da Terceira S.A. companies).

Considering the high generation costs using fossil fuels, geothermal is a competitive source of energy, providing significant running savings to EDA S.A..

In Mainland, at present, and besides a few district heating operations at existing Bath Spa's, there are no direct use projects running based in deep wells, and it is not envisaged the oncoming of new operations based in deep wells.

Portugal like the other Mediterranean countries has more leveled heating and cooling needs than Nordic

countries. As a consequence, in Portugal GSHP's are usually reversible, producing heat and cooling. The equilibrium between heating and cooling in a dwelling is important in order to maintain the temperature stability of ground along the years.

In the residential sector, heating needs are higher than cooling needs, what can lead to the ground temperature decrease. However that problem is smaller than in northern and central European countries. Commercial buildings can have more cooling needs, function of the activity developed in the building, so special attention has to be paid to geothermal borehole heat exchangers (BHE) design to avoid the ground temperature increase.

2. GEOLOGY AND HYDROGEOLOGY BACKGROUND

Geology and hydrogeology controls the occurrence of geothermal resources, so a general description of these conditions is provided below, following a previous update report (e.g. Carvalho et al., 2015).

2.1 Mainland

In Mainland Portugal, classical geothermal resources are generally associated to the following origins: i) thermo-mineral waters related to active faulting and diapirism; and ii) deep circulation in some peculiar structures in the basement and particularly in the sedimentary borders trough permeable formations.

The existing temperatures restrain the utilization to direct uses. Twenty-four springs are officially used in balneotherapy having discharge temperatures between 25 °C and 76 °C (Figure 3).

From the lithological point of view, main rocks are granites of the Variscan orogeny and metasediments pre and post orogenic. Weathering is quite irregular depending on tectonics and present and past climates. Average reported depths to sound rock ranges from 0 to 60 m but in the vicinity of main tectonic axis it is not infrequent to drill up to 300 m of weathered rock.

Naturally available discharging flows from former exploitation systems reached a maximum of 10 L/s. New wells up to 1,000 m depth, drilled after the seventies of the past century, allowed moderate improvements in sustainable production and in temperature (Carvalho, 2006).

Regarding chemistry, the following groups could be considered at the Variscan Massif: (i) hypo-saline waters with total dissolved solids (TDS) less than 150 ppm, and frequently under 50 ppm. This less mineralized group corresponds mainly to water circulating in quartzite reservoirs, (ii) sulphurous waters with up to 1,000 ppm and temperatures up to 62 °C, and (iii) carbonated sparkling waters with TDS up to 2500 ppm and temperatures up to 76 °C.

The sedimentary borders composed of sequences of post Palaeozoic sediments with thickness up to 4,000 m also present several thermal waters related to deep

faulting and diapiric tectonics. These waters are generally of the sodium chloride type and temperature from 20 to 40 °C.

A synthesis of the Portuguese geological conditions related to mineral water and geothermal can be found on DGEG (2017).




Figure 3: Geological map of Portugal Mainland and thermal occurrences (in: DGEG, 2017).

2.2 Azores Islands

The nine islands that form the archipelago of Azores are spread over 600 km in the Atlantic Ocean, along a WNW-ESE trend and emerge from the designated “Azores Plateau” (Figure 2), which is defined by the bathymetric line of 2,000 m. Being situated at the junction of the North American, Eurasian and African tectonic plates, the Azores display an intense seismic and volcanic activity. Since discovery and settlement of the islands, in early 15th century, 26 eruptions were recorded inland and onshore. Volcanic and seismotectonic activity are more concentrated in the Central Group and in the S. Miguel islands, those at the plate boundary between the Eurasian and African plates (cf. Figure 2).

On the island of S. Miguel, there are three active polygenetic volcanoes with caldera that produced mostly explosive trachytic *s.l.* eruptions in recent times: Sete Cidades, Furnas and Fogo/Água de Pau volcanoes. A fourth silicic polygenetic volcano with caldera (e.g. Povoação volcano) and two Basaltic

Fissural Areas (e.g. the Picos and Nordeste Complexes) complete the volcanic systems of S. Miguel island (Figure 4).

The Ribeira Grande Geothermal Field is located on the northern slopes of the Fogo central volcano (Figure 5) and this liquid-dominated high enthalpy system reaches maximum temperatures of about 245°C in depth.

Surface geothermal manifestations are spread on those three active central volcanoes of S. Miguel Island, which are particularly impressive at Furnas volcano caldera, with the presence of about 30 thermal springs and fumaroles.




Figure 4: Volcanological map of S. Miguel Island (Nunes, 2004). The RGGF concession area is outlined.




Figure 5: Generalized cross section of the Ribeira Grande geothermal system (adapted from GeothermEx, 2008).

On Terceira Island (Figure 6), which has a complex tectonic setting, there are four central volcanoes with caldera (Cinco Picos, Guilherme Moniz, Santa Bárbara and Pico Alto – in decreasing age sequence) and the Fissural Basaltic Zone, in the central and SE part of the island (Nunes, 2000). The Pico Alto volcano (the younger polygenetic volcano) is dominated by silicic formations of pyroclasts, domes and *coulées* of trachytic and pantelleritic nature.

At surface, the Pico Alto Geothermal Field encompasses mostly Pico Alto volcano and the Fissural Basaltic Zone formations (Figure 6), but the geothermal systems develops on a complex volcanological setting, that encompasses the interference of the Pico Alto (PA), Guilherme Moniz (GM) and even Santa Bárbara central volcanoes formations (Figure 7). This high enthalpy system reaches temperatures of about 300°C in depth.

Surface geothermal manifestations are reported in all islands but Corvo and Santa Maria islands. Presently four Thermal Baths/Spas using geothermal resources

are installed in S. Miguel and Graciosa islands. In addition, the Caldeira Velha, Poça da Dona Beija and Parque Terra Nostra (S. Miguel Island) are also thermal attractions as well-being facilities.




Figure 6: Volcanological map of Terceira Island (Nunes, 2000). The PAGF concession area is outlined.




Figure 7: General N-S cross section of Terceira Island, including the Pico Alto Volcano (PA) geothermal area (adapted from TARH & ÍSOR, 2016).

3 GEOTHERMAL UTILISATION

Geothermal energy in Portugal is used for electricity production, for direct use associated with thermal baths/Spas and in Ground Source Heat Pumps.

3.1 Electric Power Installation and Generation

At the Ribeira Grande Geothermal Field, S. Miguel Island, two geothermal power plants – Ribeira Grande and Pico Vermelho – are in operation with a net combined installed capacity of 27.8 MW (Table B). Both plants are based on ORC binary systems.

The Ribeira Grande plant consists of four dual turbo-generators developed in two phases: Phase A (2 x 2.9 MW) installed in March 1994, and Phase B (2 x 4.5 MW) completed in November 1998. The 13 MW Pico Vermelho plant started operating in November 2006 and replaced the former 3 MW pilot unit, in operation since 1980. All the geothermal brines resulting from the operation of these two geothermal power plants are re-injected.

Following the 2013/2014 campaign of short and long term tests performed on existing production wells at the Pico Alto Geothermal Field (Terceira Island), a 4 MW geothermal pilot power plant was installed in the

central part of the island (Table B), in the Pico Alto volcano and close to the fumarolic field of Furnas do Enxofre. This power plant started in operation in August 2017 and was officially inaugurated in November 2017.

Simultaneously, extensive geological, hydrogeological, geochemical and geophysical exploration campaigns, under the coordination of TARH, Lda., were carried out in 2013/2014 aiming to improve the knowledge on the area and also to allow the delineation of a comprehensive conceptual model for the PAGF. This conceptual model was considered by EDA RENOVÁVEIS S.A. a management tool to reevaluate the geothermal resource and to design and locate new wells (TARH & ISOR, 2016), which will be drilled in 2020.

Nowadays no direct uses related with the geothermal brines are in operation in the Azores Islands.

3.2 Direct Heat Uses

Direct use application in Mainland and Azores is restricted to small district heating operations and mainly balneological applications. The situation was reported recently, namely by Carvalho et al. (2013), Carvalho et al. (2015), Lourenço (2016), Nunes et al. (2016) and DGEG (2017), and no significant changes are to be mentioned.

3.2.1 District Heating

Two main operations are running normally in thermal baths:

- Chaves, Northern Portugal: a dedicated well, 150 m deep, 76 °C, TDS of 2500 mg/L, 5 L/s capacity, in metamorphic slates with quartz veins, is used in a small district heating network (swimming-pool and hotel). An independent well (100 m deep, 73 °C, TDS of 2500 mg/L, 10 L/s capacity), tapped hot water in metamorphic slates with quartz veins and feeds the Thermal Bath.
- S. Pedro do Sul, central Portugal, the main Portuguese Spa: one inclined well, 500 m deep, 69 °C, 350 mg/L TDS, 10 L/s with artesian flow, in fractured granite, supply the Thermal Bath and is in use in a small heating operation, financed by the THERMIE Program, in two hotels and inside the Spa.

Several minor district heating operations are running in Caldas de Monção, Termas da Longroiva and Alcafache in Mainland and at Furnas hotels, in S. Miguel (Azores archipelago).

3.2.2 Bathing and Swimming

Balneological activities using thermo-mineral waters are quite popular in Portugal for cure and touristic purposes. About 30 Thermal Baths are operating within a legal framework (cf. DGEG, 2017). Most are open only in summer, but some of them are operating normally all over the year. All the balneological

activity inside the baths is carried out under strict medical control.

Since 2004 the INOVA Institute and the Azores Government undertake several initiatives and studies allowing the exploitation and valuing of the Azorean low temperature geothermal resources for direct use, including touristic activities and balneology (e.g. Nunes et al., 2015). Associated with these activities new shallow wells were carried out in Ferraria (S. Miguel), Varadouro (Faial) and Carapacho (Graciosa).

3.3 Ground Source Heat Pumps

According to the last data recorded by EHPA, European Heat Pump Association, there were no new sales of GSHP in Portugal in 2014. The aggregated sales until 2014 was about 54 units with an installed capacity of 0.65 MW. Considering typical values, the averaged installed capacity was 12 kW, with an operating hours value of 1,340 and a typical Seasonal Performance Factor (SPF) of 3.425. For the years after 2014, it was not possible to obtain data. It is difficult to follow the evolution of new projects concerning GSHP, since Portugal still doesn't have legislation to oblige the registration of this kind of project, especially concerning the residential sector. It is possible that a greater number of small installations are performed each year, but are not registered.

With a view to increase the knowledge in this area and inherently to promote the dissemination and proper use of GSHP, four national entities (DGEG, LNEG, APG and ADENE) established a collaboration protocol concerning the creation of a baseline study, analysis and dissemination of geothermal use through GSHP. The Portuguese Platform of Shallow Geothermal Energy (PPGS) was created in 2013 with the mission to disseminate the best practices involving GSHP, to promote the dialogue on geothermal community, to collaborate on new legislation, spread knowledge of technical standards and procedures, contributing to the training of the agents involved and to promote the development of new projects. However due to the weak interest in the application of shallow geothermal energy in Portugal, this platform ended its activity in 2017.

One of the gaps in Portugal for the development of shallow geothermal energy is the lack of a legal framework.

A new legislative framework concerning shallow geothermal purposes began to be prepared about 5 years ago and only at the end of last year did it pass to the Portuguese parliament to be approved. It is expected that during the year 2019 this legislative framework to enter in force. This legislative framework imposes the obligation to register the installed GSHPs. So, it is expected to have statistical data of new installations in the near future.

In spite of the lack of registration, there is some information about GSHP projects developed in

Portugal that are presented below (see also Carvalho et al., 2013, Edificios e Energia, 2013, Cardoso & Lapa, 2015a; 2015b, Ferreira, 2019):

- Brigantia Ecopark in Bragança: it is equipped with three GSHP, one just for domestic hot water (DHW) heating and two for the building acclimatization. To dissipate the heat generated by the GSHP 45 boreholes, with a depth of 120 m, were performed. Regarding GSHP for DHW, only heat is produced and the system is interconnected with DHW reservoir. Concerning the other two GSHP, for acclimatization, heat and cool is produced and the system is connected to a buffer tank of 9,000 L. When the tanks are full, the excess of heated/cooled water is dissipated into the boreholes heat exchangers. Under this building there is a set of tubes to serve as an air inflow pre-heating to reduce energy consumption, thereby improving the system efficiency;
- Aveiro University (ECORR, ESAN, CCI, CICFANO and ESSUA buildings): Aveiro university has 5 buildings acclimatized with GSHP. Table 1 resumes the main properties of the installation;
- Superior School of Technology of Setúbal (EST Setúbal): the Polytechnic Institute of Setubal, that was a partner in GROUNDHIT European Project (6th Framework Program), has a demonstration site for high energy efficiency GSHP's. Two GSHP's of 15 KWt for heating and 12 KWt for cooling, each, were installed in the thermodynamics laboratory, to acclimatize 7 office rooms with areas between 13 and 17 m² and 2 classrooms with 63 and 65 m². The project aimed at monitoring the prototype of improved energy efficiency heat pumps (COP higher than 5.5) in real conditions in a Mediterranean climate, and test two different Boreholes Heat Exchangers (BHE) types: double-U pipes and coaxial pipes. The demo site results showed that the GSHP's COP is according to the expected ones during the design phase (COP of 5.19 for cooling and 6.05 for heating in real conditions), with a good performance in the terminal units (fan-coils, secondary circuit), boreholes (primary circuit) and GSHP;
- Regional authority administration building in Coimbra: the second example is another European project (7th Framework Program) called GROUNDMED, that aims at verifying sustainability of heat pump technology for heating and cooling of buildings in a Mediterranean climate. The Portuguese GROUNDMED installation is set on a regional authority administration building with offices and laboratories, located in Coimbra city. One GSHP with a heating capacity of 56 kWt and cooling capacity of 61 kWt (Eurovent conditions) serves the building 3rd floor offices. The GSHP is coupled to seven double U, 125 m vertical borehole heat exchangers. The heating/cooling distribution system consists of 33 ceiling Coanda effect fan coil units with high efficiency permanent magnet

EC motors, installed in 22 offices, with a total area of 600 m². Since all systems were designed to function with moderated temperatures the real cooling capacity is 63.5 kWt and the real heating

capacity is 70.4 kWt, resulting in an increased performance. The results showed good results with a GSHP COP of 5.65 and an EER of 6.19;

Table 1: Main properties of the Aveiro University GSHP installation.

Designation	Year	Local	Building area (m ²)	Floors	Acclimatization area (m ²)	Annual heating needs (kWh)	Annual cooling needs (kWh)	Number of GSHP	GSHP COP	Thermo-active Foundations	BHE	Complement
ESSUA	2011	Campus de Crasto	3564	3	7660	612800	383000	4	4.3	147 thermal piles with Ø 600mm and 8m deep, "U" vertical polyethylene heat exchangers with Ø 32mm	22 BHE Ø 150mm, double "U" vertical polyethylene heat exchangers with Ø 32mm, 150m deep	
CICFANO	2012	Campus de Santiago	1600	3	3560	284800	178000	1	4.3	55 thermal piles with Ø 600mm and 30 thermal piles with Ø 400mm, 10m deep, "U" vertical polyethylene heat exchangers with Ø 25mm		Thermal use of waste water effluents
ESAN	2013	Santiago de Riba-UI	4170	1	4088	327040	204400	4	4.3		34 BHE Ø 150mm, "U" vertical polyethylene heat exchangers with Ø 40mm, 150m deep	Solar panel
ECOCRR	2014	Campus de Santiago	2954	1	2240	179200	112000	1	4.3		22 BHE Ø 150mm, "U" vertical polyethylene heat exchangers with Ø 40mm, 120m deep	
CCCI	2015	Campus de Santiago	1600	3	3300	264000	165000	1	4.3		42 BHE Ø 160mm, "U" vertical polyethylene heat exchangers with Ø 40mm, 130m deep	Solar panel

- Sines Tecnopolis: this complex, that includes heating, cooling and domestic hot water production, has an existing renewed building with 251 m², a laboratory building with 534 m² and an office building with 1,286 m², all served by GSHP's. The existing renewed building is served by one GSHP with a heating capacity of 24.5 kWt and cooling capacity of 18.4 kWt, coupled to 2 simple U, 150 m vertical borehole heat exchangers;
- Aveiro University has been also collaborating with "Chama Energia" company in other projects as listed in Table 2;
- Ombria Resort, Algarve: This resort includes one golf course, the club house, one hotel, one Spa and some villas. This is the largest installation of shallow geothermal energy in Portugal. At the

moment it is in the final phase of the installation, being completed this year. The total needed capacity based in GSHP is about 2370 kW of heating and 1100 kW of cooling. The club house has an area of 1,260 m² and the hotel, spa and villas have an area of 15,940 m². For the club house were installed 40 BHE with 100 m depth each, for the hotel were installed 60 BHE with 125 m depth each and for the spa and villas, 144 BHE with 115 m depth each. Solar collectors (vacuum type) for DHW, hot water for the swimming pools and also to inject heat in the ground through the BHE to equilibrate the balance of energy injected and extracted by the GSHP along the year, were installed. A total of 108 solar collectors was installed for the club house, and 48 solar collectors for the hotel.

Table 2: GSHP projects of “Chama Energia” company, in cooperation with the Aveiro University.

Designation	Year	Local	Building area (m ²)	Floors	Acclimatization area (m ²)	Annual heating needs (kWh)	Annual cooling needs (kWh)	Number of GSHP	GSHP COP	BHE	Complement
EB23 Mortágua	2009	Mortágua	4300	3	4300	344000	215000	1	4.8	50 BHE Ø 160mm, "U" vertical polyethylene heat exchangers with Ø 40mm, 100m deep	Solar painel
Hotel Aqua Village 5*	2015	Caldas São Paulo	6000	1	6000	480000	300000	1	6.2	33 BHE Ø 160mm, "U" vertical polyethylene heat exchangers with Ø 40mm, 150m deep	Solar painel
Hotel Stroganov 5*	2015	Fiais da Beira	320	3	960	76800	48000	1	4.3	10 BHE Ø 160mm, "U" vertical polyethylene heat exchangers with Ø 40mm, 100m deep	Solar painel
CE Lorbão	2014	Lorbão	650	2	1300	104000	65000	1	4.3	10 BHE Ø 160mm, "U" vertical polyethylene heat exchangers with Ø 40mm, 100m deep	Solar painel
CE Santa Comba Dão	2011	SCD	2200	1	2200	176000	110000	1	4.8	15 BHE Ø 160mm, "U" vertical polyethylene heat exchangers with Ø 40mm, 100m deep	Solar painel
CE Santa Comba Dão	2011	SCD	1600	2	3200	256000	160000	2	4.8	18 BHE Ø 160mm, "U" vertical polyethylene heat exchangers with Ø 40mm, 100m deep	Solar painel
CE Santa Comba Dão	2011	SCD	1400	3	4200	336000	210000	1	4.8	20 BHE Ø 160mm, "U" vertical polyethylene heat exchangers with Ø 40mm, 100m deep	Solar painel
Centro Balmar	2007	Mortágua	1300	2	2600	208000	130000	1	5.0	14 BHE Ø 160mm, "U" vertical polyethylene heat exchangers with Ø 40mm, 100m deep	Solar painel
APPC Viseu	2013	SC Dão	1250	1	1250	100000	62500	1	4.4	10 BHE Ø 160mm, "U" vertical polyethylene heat exchangers with Ø 40mm, 100m deep	Solar painel
M. Coruche	2010	Coruche	2800	1	2800	224000	140000	2	4.1	18 BHE Ø 160mm, "U" vertical polyethylene heat exchangers with Ø 40mm, 100m deep	Solar painel
APPC Castelo Branco	2012	C. Branco	2200	1	2200	176000	110000	1	4.1	10 BHE Ø 160mm, "U" vertical polyethylene heat exchangers with Ø 40mm, 130m deep	Solar painel

4. CONCLUSIONS

In Portugal, the presence of high temperature geothermal resources and the production of electricity from geothermal resources are restricted to the volcanic islands of Azores Archipelago.

Presently EDA RENOVÁVEIS S.A. has a total installed generation capacity in S. Miguel Island Azores of 27.8 MW net in two geothermal power plants. Those power plants ensured the production in 2018 of 183.6 GWh_e in S. Miguel Island, that represents 42% of the electrical consumption of the island, and 23.1% of the total demand of the archipelago. Power production is stabilized since 2013 and new wells are expected to be drilled in 2020 to increase the total running capacity of the Ribeira Grande and Pico Vermelho power plants up to 30 MW.

On Terceira Island, the 4 MW Pico Alto pilot power plant (that started operating in August 2017) ensured the production in 2018 of 20.6 GWh_e, that represents 10.8% of the electrical consumption of the island, and 2.6% of the total demand of the archipelago.

Low-temperature geothermal resources in Mainland Portugal are exploited for direct uses in balneotherapy and small district heating systems.

Concerning GSHP's the potential is huge and is starting to be exploited, with new projects ongoing and new regulations is expected to be approved this year 2019. There are a few installations registered until 2014, but the registration data of the installations are scarce and do not represent the totality of what is installed in Portugal. However this tends to change

due to the preparation of new legislation for regulating shallow geothermal operations.

The Ombria Resort installation, the largest shallow geothermal energy in Portugal will be completed during 2019 and could be an interesting case study about the use of this renewable energy source to promote and disseminate this technology in Portugal

In fact, a new legislation draft on GSHP's was already prepared by the Directorate General for Energy and Geology (DGEG) – the Portuguese authority for those geological resources – that will contribute not only to ameliorate the quality of the operations, but also to allow future statistical data to be more realistic.

In addition, in 2018 it was released a call for geothermal projects, sponsored by the FAI – “Fundo de Apoio à Inovação”, to promote the use of geothermal resources in Portugal, namely the low enthalpy resources associated with Thermal Baths/Spas facilities. For the time being, two district heating networks for hotels and public buildings were retained for funding: (i) S. Pedro do Sul (67°C, 17 L/s) with a proposed 5 km network, and (ii) Chaves (74°C, 15 L/s) with 3 km extension; field work will be performed in 2019/2020.

REFERENCES

- Cardoso, C. and Lapa, J.: A geotermia na sustentabilidade de campi universitários: os casos de estudo do edifício cicfano e da escola superior de saúde, *PPGS Newsletter 3*, (2015a), 6-9.
- Cardoso, C. and Lapa, J.: A geotermia na sustentabilidade de campi universitários: os casos de estudo dos edifícios de comunicações óticas, da escola superior Aveiro Norte comunicações rádio e robótica e do complexo do departamento de comunicação e arte, *PPGS Newsletter 4*, (2015b), 8-10.
- Carvalho, J.M.: *Prospecção e pesquisa de recursos hídricos subterrâneos no Maciço Antigo Português: linhas metodológicas*, Universidade de Aveiro, 292 pp, PhD Thesys, (2006), <http://biblioteca.sinbad.ua.pt/teses/2007000122>.
- Carvalho, J.M., Coelho, L., Nunes, J.C. and Carvalho, M.R.: Geothermal Energy Use, Country update for Portugal, *Proceedings of the European Geothermal Congress 2013, Pisa, Italy*, (2013), paper CUR-24, 11 pp. (Cd-Rom Edition).
- Carvalho, J.M., Coelho, L., Nunes, J.C., Carvalho, M.R., Garcia, J. and Cerdeira, R.: Portugal Country update 2015, *Proceedings of the World Geothermal Congress 2015, Melbourne, Australia*, (2015), paper #01065, 11 pp.
- DGEG: *Geotermia - Energia Renovável em Portugal*. DGEG - Direção Geral de Energia e Geologia, (2017), Electronic Edition, 54 pp., ISBN: 978-972-8268-44-2.
- Edifícios e Energia Magazine: Issue Nov./Dec., (2013).
- Ferreira, G.: Geotermia aplicada aos sistemas de climatização do Ombria Resort. *Curso de Formação “Introdução aos sistemas geotérmicos superficiais”*, VIII Jornadas APG, Lisboa, Portugal (2019), 20-21 February, ppt presentation.
- GeothermEx: Update of the conceptual and numerical model of the Ribeira Grande Geothermal Reservoir, São Miguel, Açores. *Sociedade Geotérmica dos Açores S.A. Internal Report*, (2008), 190 pp.
- Lourenço, C.: Geothermal resources, natural mineral and spring waters: an overview, *PIMBIS 2016–Portugal International Mining Business & Investment Summit*, Lisbon, April 12th-14th, (2016), pdf pps presentation.
- Nunes, J.C.: Notas sobre a geologia da Ilha Terceira (Açores), *Açoreana, 9 (2)*, Ponta Delgada, (2000), 205-215.
- Nunes, J.C.: Geologia, in: *Atlas Básico dos Açores*, Forjaz, V.H. (Ed.), 60-62, *Observatório Vulcanológico e Geotérmico dos Açores*, Ponta Delgada, (2004).
- Nunes, J.C., Lima, E.A. and Medeiros, S.: *Carta de geossítios da Ilha de Santa Maria*, 1/50,000 scale, Universidade dos Açores, Departamento de Geociências (Ed.). ISBN: 978-972-8612-47-4, (2008).
- Nunes, J.C., Carvalho, J.M. and Olivera, L.C.: Águas termais dos Açores: passado, presente e futuro, *Balnea, 10*, Madrid, (2015), 279-288. ISBN: 978-84-606-9368-0.
- Nunes, J.C., Coelho, L., Carvalho, M.R., Garcia, J., Cerdeira, R. and Carvalho, J.M.: Geothermal energy use, country update for Portugal. *Proceedings of the European Geothermal Congress 2016*, Strasbourg, France, (2016), 11 pp. (Cd-Rom Edition).
- TARH & ÍSOR: Conceptual model of the Pico Alto Geothermal Field, Terceira Island, Azores, Final Report. *EDA RENOVÁVEIS S.A. Internal Report*, (2016), 73 pp.
- Acknowledgements**
- The authors would like to thank: EHPA, University of Aveiro (Prof. Cláudino Cardoso and Prof. José Lapa) and also “Chama Energia” (Eng. Paulo Santos) for their good will and information shared and also Eng Luis Fernando Silva (ADENE) for the support regarding the Portuguese statistics on renewable energy.
- We also thank EDA – Electricidade dos Açores S.A. for providing and allowing the use of data concerning the Ribeira Grande and Pico Alto geothermal fields, Azores Islands.

Tables A-G**Table A: Present and planned geothermal power plants, total numbers**

	Geothermal Power Plants		Total Electric Power in the country		Share of geothermal in total electric power generation	
	Capacity (MW _e)	Production (GWh _e /yr)	Capacity (MW _e)	Production (GWh _e /yr)	Capacity (%)	Production (%)
In operation end of 2018 *	26	204.2	20378	59432	0.13	0.34
Under construction end of 2018	0	0	not available	not available	not available	not available
Total projected by 2020	0	0	not available	not available	not available	not available
Total expected by 2025	36	285	not available	not available	not available	not available
In case information on geothermal licenses is available in your country, please specify here the number of licenses in force in 2018 (indicate exploration/exploitation if applicable):					Under development**: 2	
					Under investigation**:	

Table B: Existing geothermal power plants, individual sites

Locality	Plant Name	Year commis- sioned	No of units **	Status	Type	Total capacity installed (MW _e)	Total capacity running (MW _e)	2018 pro- duction * (GWh _e /y)
Ribeira Grande (S. Miguel Island, Azores)	Pico Vermelho	2006	1 (RI)	O	B-ORC	13.0	13	101.4
Ribeira Grande (S. Miguel Island, Azores)	Ribeira Grande	1994/ 1998	4 (RI)	O	B-ORC	14.8	10	82.2
Pico Alto (Terceira Island, Azores)	Pico Alto	2017	1 (RI)	O	B-ORC	4	3	20.6
total						31.8	26	204.2
Key for status:			Key for type:					
O	Operating	D	Dry Steam		B-ORC	Binary (ORC)		
N	Not operating (temporarily)	1F	Single Flash		B-Kal	Binary (Kalina)		
R	Retired	2F	Double Flash		O	Other		

Table C: Present and planned deep geothermal district heating (DH) plants and other uses for heating and cooling, total numbers

	Geothermal DH plants		Geothermal heat in agriculture and industry		Geothermal heat for buildings		Geothermal heat in balneology and other **	
	Capacity (MW _{th})	Production (GWh _{th} /yr)	Capacity (MW _{th})	Production (GWh _{th} /yr)	Capacity (MW _{th})	Production (GWh _{th} /yr)	Capacity (MW _{th})	Production (GWh _{th} /yr)
In operation end of 2018 *	2.1	15	0	0	1.0	7	17.1	85.9
Under construction end 2018	0	0	0	0	0	0	0	0
Total projected by 2020	10	70	not available	not available	not available	not available	not available	not available
Total expected by 2025	10	70	not available	not available	not available	not available	20	111

Table D1: Existing geothermal district heating (DH) plants, individual sites

Locality	Plant Name	Year commissioned	CHP **	Cooling ***	Geoth. capacity installed (MW _{th})	Total capacity installed (MW _{th})	2018 production* (GWh _{th} /y)	Geoth. share in total prod. (%)
Chaves	Chaves	1982/2015	N	N	0.8	not available	6.7	
S. Pedro do Sul	S. Pedro do Sul	2000/2015	N	N	1.2	not available	8.3	
total					2		15	

Table D2: Existing geothermal large systems for heating and cooling uses other than DH, individual sites

Locality	Plant Name	Year commissioned	Cooling **	Geoth. capacity installed (MW _{th})	Total capacity installed (MW _{th})	2018 production* (GWh _{th} /y)	Geoth. share in total prod. (%)	Operator
Monção			N	not available	not available	not available		
Alcafache			N	not available	not available	not available		
Longroiva			N	not available	not available	not available		
Furnas (Azores)		2016	N	not available	not available	not available		
total								

Table E: Shallow geothermal energy, ground source heat pumps (GSHP)

	Geothermal Heat Pumps (GSHP), total			New (additional) GSHP in 2018 *		
	Number	Capacity (MW _{th})	Production (GWh _{th} /yr)	Number	Capacity (MW _{th})	Share in new constr. (%)
In operation end of 2018 *	54*	0.65*	0.871*	not available	not available	not available
Projected total by 2020	not available	not available	not available			

* values for 2015, no further data available

Table F: Investment and Employment in geothermal energy

	in 2018 *		Expected in 2020	
	Expenditures ** (million €)	Personnel *** (number)	Expenditures ** (million €)	Personnel *** (number)
Geothermal electric power	EDA RENOVÁVEIS S.A.	EDA RENOVÁVEIS S.A.	EDA RENOVÁVEIS S.A.	EDA RENOVÁVEIS S.A.
Geothermal direct uses	not available	not available	not available	not available
Shallow geothermal	not available	not available	not available	not available
total				

Table G: Incentives, Information, Education

	Geothermal electricity	Deep Geothermal for heating and cooling	Shallow geothermal
Financial Incentives – R&D	Portugal 2020 and Horizon 2020 (EU)	Portugal 2020 and Horizon 2020 (EU)	Portugal 2020 and Horizon 2020 (EU)
Financial Incentives – Investment	no	no	no
Financial Incentives – Operation/Production	no	no	no
Information activities – promotion for the public	Some punctual information activities	Some punctual information activities	Some punctual information activities
Information activities – geological information	Some punctual information activities	Some punctual information activities	Some punctual information activities
Education/Training – Academic	A few academic courses	A few academic courses	A few academic courses
Education/Training – Vocational	A few academic courses	A few academic courses	A few academic courses
Key for financial incentives:			
DIS	Direct investment support	FIT	Feed-in tariff
LIL	Low-interest loans	FIP	Feed-in premium
RC	Risk coverage	REQ	Renewable Energy Quota
-A	Add to FIT or FIP on case the amount is determined by auctioning		
O	Other (please explain)		